HIGEN					ION MOTOR A SHEET				0.4	kW - 4	Р	
MODEL:	KMI-400V6F		CUSTOMER :		_			REV. N	0 :			
APPLICATION	:							TTY :				
			PERFOR				E DAT	A				
FRAME NO.			OUTP	OUTPUT			0.4 kW					
		DRIP	POLE	POLES			4 POLES					
ENCLOSURE		✓ ΤΟΤΑ	ROTOR TYPE			SQUIRREL CAGE						
		🗌 Increa	f				✓ D.O.L □ Y-					
PROTECTION		IF	STAR	STARTING METHOD			REACTOR ( %TAP) V.V.V.F					
METHODS OF COOLING		🗌 SC				SOFT-STARTER						
FREQUENCY		60 Hz		RATE	RATED VOLTAGE			440 V V V				
PHASE		3	CURRENT									
SERVICE FACTOR		1.15	NO LOAD				А	А	A			
INSULATION CLASS		В	F	FULL LOAD			1.1	Α	А	A		
TEMP. RISE AT FULL LOAD (at S		S.F 1.0)			STARTING			7.2	Α	А	A	
RES. METHOD		85	EFFICIENCY									
THERMO. METHOD			ļ	AT 1/2 LOAD			%					
LOCATION			. /	AT 3/4 LOAD			%					
ALTITUDE		1000	1	AT FULL LOAD			75.0 %					
HUMIDITY		80	POW	POWER FACTOR								
AMBIENT TEMPERATURE		-10~40	ļ	AT 1/2 LOAD					%			
RATING		CONT. 860		1	AT 3/4 LOAD			%				
NEMA DESIGN		V		AT FULL LOAD			63.0 %					
MOUNTING		□ B3 □ B5 ✓ V1 □ B3B5		SPEE	SPEED (AT FULL LOAD)			1710 rpm				
BEARING TYPE		BALL		TORC	TORQUE							
	DE\N-DE	e	5203ZZ/6203ZZ	F	FULL LO	AD		(	).2	kg-m	100%	
LUBRICANT			LOCKED ROTOR			(	0.4 kg-m		200%			
COUPLING METHOD			BREAKDOWN			0.4 kg-m		200%				
SHAFT				NOISI	NOISE LEVEL			61.0 dB(A		4)		
EXTENSION		SINGLE		VIBRATION			15.0 <b>μ</b> m					
EXTERNAL THRUST				ALLO	ALLOWABLE LOAD GD <sup>2</sup> REFERRE			D TO MC	TOR SH	HAFT		
TERMINAL BOX				(AT DIRECT ON-LINE)			2.4 kg-m <sup>2</sup>			2		
MAIN		✓ STEE		Motor	Motor GD <sup>2</sup>			0.0079		kg-m		
AUX.		<b>YES</b>	✓ NO	MOTO	MOTOR APPROX. WEIGHT		iHT	13.0 kg				
BOX LOCATION		LEFT (\	/iewed from Drive end)	PAINT	TING	MUNSELL NO.		7.1B4		7.1B4.0/0.9		
APPLICATION STANDARDS		IEC, KS			THICKNESS		SS	STANDARD		$\mu$ m		
	ACCESSORI	ES (OPTI		SUBMITT			AL DRAWINGS					
NOTE					REMARKS							
1. THESE DATA ARE ONLY DESIGN VALUES AND SHALL BE GUARANTEED WITH TOLERANCE OF APPLICATION STANDARDS.					1. ABOVE ALL DATA ARE CALCULATED AT 100% VOLTAGE.							
2. OTHERS NOT												
IN ACCORDANCE WITH OTIS STANDARD. FC : FAN COOLED SC : SELF COOLED					DATE PREPA				CHEC	יעבח	APPROVED	
	LLV	JU . JELF	UUULLU					ARK	H.K.		H.J.KIM	