Н	GEI	INDUCTION MOTOR DATA SHEET			R	1.5 kW - 2 P							
MODEL: KMI-	02HK3		CUSTO	OMER :				REV. N	0 :				
APPLICATION:			PROJE	ECT NAME:					QUANTITY:			SETS	
GENERAL DATA							PERFORI	RMANCE DATA					
FRAME NO.		90L			OUTPUT			1.5		kW	2	HP	
		DRIP	DRIP PROOF			POLES			2 POLES				
ENCLOSURE		✓ TOTA	TOTALLY ENCLOSED			ROTOR TYPE			SQUIRREL CAGE				
		Increa	sed Sa	fety Expproo	f			✓ D.0	O.L	Y-			
PROTECTION		IF	IP 44			STARTING METHOD		RE	ACT	OR ( %T/	4P) [	V.V.V.F	
METHODS OF COOLING		SC FC DP						☐ VECTOR DRIVE					
PHASE		3 PHASE			RATED VOLTAGE			220	V	380	٧	V	
SERVICE FACTOR		1.15			FREQUENCY			60 Hz					
INSULATION CLASS		B CLASS			CURRENT								
TEMP. RISE AT FULL LOAD (at		S.F 1.0)			NO LOAD				Α		Α	А	
RES. METHOD		80			FULL LOAD			6.2	Α	3.6	Α	А	
THERMO. METHOD					STARTI	NG		36.9	Α	21.4	Α	А	
LOCATION		✓ INDC	OR [		EFFICIENCY								
ALTITUDE	1000 m			AT 1/2 LOAD			%						
HUMIDITY	90 %			AT 3/4 LOAD			%						
AMBIENT TEN	-10~40			AT FULL LOAD			79.0 %						
RATING		✓ CONT.			POWER FACTOR								
NEMA DESIGI	В			AT 1/2 LOAD					(	%			
MOUNTING	☑ B3 ☐ B5 ☐ V1 ☐ B3B5			AT 3/4 LOAD			%						
BEARING TYPE		BALL			AT FULL LOAD			8	1.0	(	%		
	DE\N-DE	6	5205ZZ/6	5204ZZ	SPEED (AT F	ULL LOAD	)	3-	450	ı	pm		
	LUBRICANT		GRE <i>A</i>	ASE	TORQUE								
COUPLING MI	✓ DIRECT			FULL LOAD			0	.42	kg-m	100%			
ROTATION(Fa	□ cw ✓ ccw			LOCKED ROTOR			0	.76	kg-m	180%			
SHAFT				BREAKDOWN			0	.85	kg-m	200%			
EXTENSION		SINGLE			NOISE LEVEL			-	75	(			
EXTERNAL THRUST					VIBRATION			3	0.0		μm		
TERMINAL BO				ALLOWABLE	LOAD GD <sup>2</sup>	<sup>2</sup> REFERREI	ото мо	TOR S	SHAFT				
MAIN		✓ STEE	L 🗌 A	L CAST	(AT DIRECT	ON-LINE)		1	.6	k	g-m <sup>2</sup>		
AUX.		YES		√ NO	Motor GD <sup>2</sup>	·		0.0	128		g-m <sup>2</sup>		
		/iewed fr	om Drive end)	MOTOR APP	ROX. WEIC	GHT		21		kg			
APPLICATION STANDARDS			KS.II		PAINTING	MUNSEL				7.1 B 4.0/0	-		
						THICKNE	ESS	√ ST/	ANDA	RD	]	$\mu$ m	
				AL DRAWINGS									
NOTE	REMAR	REMARKS											
THESE DATA ARE ONLY DESIGN VALUES AND SHALL BE     GUARANTEED WITH TOLERANCE OF APPLICATION STANDARDS.					1. ABOV	E ALL DAT	A ARE CALO	CULATEI	O AT 1	00% VOL	TAGE		
	MENTIONED IN TH NCE WITH HIGEN S		HALL BE										
TE : TOTALLY		DP : DRIP	DDOOE		DAT	·E	PREPAI	DED	СПЕ	CKED	٨٥	PROVED	
FC : FAN COO		SC : SELF COOLED			2009-07-02 H.Y.k				I.HA		I.J.KIM		